



ICAR S.p.A. - Via Isonzo 10 - 20052 Monza (MI) - ITALY

QUALITY AND CONFORMITY

Delivery Note : _____

N° _____

Capitale € 10.000.000 i.v.

AFFIDAVIT N°**100720 (200470)**

Date _____

Lot. N°/Date **10 - 29 - 369**Model : **CRT E 100208 15 415**Customer : **HUNYADI**Quantity : **30**Capacitance : **149,2** $\mu\text{F} \pm -5/+10$ %Order: **IKT/2010/3308**Date: **16/06/2010****CERTIFICATE DUE TO :** Samples First batch of production Deviation Acceptance under deviation Sistematic Inspection Periodical InspectionCHANGE : Design Equipment Treatments MaterialRef. Specif. **IEC 831 - 1 - 2**

Encl. _____

PRODUCT QUALITY CERTIFICATE

Ref.	Characteristics Inspected	Tested N°	Results	Note
1	Sealing	100 %	OK	
2	Visual examination	100 %	OK	
3	Marking	100 %	OK	
4	Dimensions	100 %	OK	
5	Voltage test terminal-terminal at 2,15 V _N x 2 "	100 %	OK	
6	Voltage test terminals-case at 3 kV x 2 "	100 %	OK	
7	Capacitance μf 149,2 <u>1000</u> Hz	100 %	OK	
8	Dissipation factor $\leq 35 \times 10^{-4}$ <u>1000</u> Hz	100 %	OK	

Note

DECLARATION OF CONFORMITY

- The material of this delivery was manufactured, inspected and tested according to relevant specifications and or drawings.

- ICAR Quality System is in accordance with UNI-EN-ISO- 9001

Operator

Quality Assurance

Date

20/07/2010

100.C.6.70F

ICAR SpA - Via Isonzo 10 - 20052 Monza (MI) ITALY
Tel. 039-83951 Fax 039 - 833227cod. fisc. 00935360156 p.iva 11220690157
r.e.a. 334221 - r.i. MI 344322 - MI 016523
Sede Legale: C.so Magenta,65 - 20123 Milano