



ICAR S.p.A. - Via Isonzo 10 - 20052 Monza (MI) - ITALY

QUALITY AND CONFORMITY

Delivery Note : _____

N° _____

Capitale € 10.000.000 i.v.

AFFIDAVIT N° _____

100702 (200470)

Date _____

Lot. N°/Date **10 - 26 - 83**

Model : **CRT E 100208 20 415**

Customer : **HUNYADI**

Quantity : **26**

Capacitance : **184,9** $\mu\text{F} \pm -5/+10$ %

Order: **IKT/2010/3308**

Date: **16/06/2010**

CERTIFICATE DUE TO :

Samples

First batch of production

Deviation

Acceptance under deviation

Systematic Inspection

Periodical Inspection

CHANGE :

Design

Equipment

Treatments

Material

Ref. Specif. **IEC 831 - 1 - 2**

Encl. _____

PRODUCT QUALITY CERTIFICATE

Ref.	Characteristics Inspected	Tested N°	Results	Note
1	Sealing	100 %	OK	
2	Visual examination	100 %	OK	
3	Marking	100 %	OK	
4	Dimensions	100 %	OK	
5	Voltage test terminal-terminal at 2,15 VN x 2 "	100 %	OK	
6	Voltage test terminals-case at 3 kV x 2 "	100 %	OK	
7	Capacitance μf 184,9 <u>1000</u> Hz	100 %	OK	
8	Dissipation factor $\leq 35 \times 10^{-4}$ <u>1000</u> Hz	100 %	OK	

Note

DECLARATION OF CONFORMITY

- The material of this delivery was manufactured, inspected and tested according to relevant specifications and or drawings.

- ICAR Quality System is in accordance with UNI-EN-ISO- 9001

Operator

Quality Assurance

Date

02/07/2010

100.C.6.70F

ICAR SpA - Via Isonzo 10 - 20052 Monza (MI) ITALY
Tel. 039-83951 Fax 039 - 833227

cod. fisc. 00935360156 p.iva 11220690157
r.e.a. 334221 - r.i. MI 344322 - MI 016523
Sede Legale: C.so Magenta,65 - 20123 Milano