



ICAR S.p.A. - Via Isonzo 10 - 20052 Monza (MI) - ITALY

QUALITY AND CONFORMITY**AFFIDAVIT N°** 100505 (200266)

Delivery Note : N° _____

Date _____

Capitale € 10.000.000 i.v.

Lot. N°/Date : **10.18.0148**Model : **CRT E 116283 37,5 525**Customer **HUNYADI GROUP LTD**Quantity : **33**Capacitance **216,6** μF **-5 / +10** %Order **IKT 2010/2077**Date **19/04/10****CERTIFICATE DUE TO :** Samples First batch of production Deviation Acceptance under deviation Sistematic Inspection Periodical Inspection

CHANGE :



Design



Equipment



Treatments



Material

Ref. Specif. **IEC 831 - 1 - 2**

Encl. _____

PRODUCT QUALITY CERTIFICATE

Ref.	Characteristics Inspected	Tested N°	Results	Note
1	Sealing	100 %	OK	
2	Visual examination	100 %	OK	
3	Marking	100 %	OK	
4	Dimensions	100 %	OK	
5	Voltage test terminal-terminal at 2,15 V_N x 2 "	100 %	OK	
6	Voltage test terminals-case at 3 kV x 2 "	100 %	OK	
7	Capacitance 216,6 μF \pm 5% 1000 Hz	100 %	OK	
8	Dissipation factor $\leq 35 \times 10^{-4}$ 1000 Hz	100 %	OK	

Note

DECLARATION OF CONFORMITY

- The material of this delivery was manufactured, inspected and tested according to relevant specifications and or drawings.

- ICAR Quality System is in accordance with UNI-EN-ISO- 9001

Operator

Quality Assurance

Date

05/05/2010

100.C.6.70F

ICAR SpA - Via Isonzo 10 - 20052 Monza (MI) ITALY
Tel. 039-83951 Fax 039 - 833227

cod. fisc. 00935360156 p.iva 11220690157
r.e.a. 334221 - r.i. MI 344322 - MI 016523
Sede Legale: C.so Magenta,65 - 20123 Milano